

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2023/School/519

Dated: 31/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Universal Public School Located at G-109, Mandir Marg, Mahavir Enclave, Palam Dabri Road, New Delhi having 02 blocks comprised of G+2 UFs (connected to each other) & 01 block G+3 UFs owned / occupied by Universal Public School was issued FSC vide Letter No. F.6/DFS/MS/School/2020/SZ/94, dated 03/03/2020 (Issued to Ground + 02 UFs), have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 22/07/2023 in the presence of Smt. Deepa Joshi (Principal) and found that the said building is fit for occupancy class "Educational" Group B Sub Division B - 1 with effect from 31/07/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 31.07.2023. at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service.

Copy to:

1. The Principal, Universal Public School, at G-109, Mandir Marg, Mahavir Enclave, Palam Dabri Road, New Delhi.
2. Directorate of Education Old Secretariat Delhi - 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).